



Address: Alderman Gee Hall CV12 8EL

Date of visit: 21/07/2020

System type: IRS

Location of Equipment: Accessible via ladders

Antennas

Inspect UHF/FM aerials, ensure they are on optimum beam, ensure secured:

Yes [x] No []

Check cables and connections

Yes [x] No []

Dishes

Check beam of dish

Yes [x] No []

Check brackets and clamps to ensure secured

Yes [x] No []

Check cable and connections

Yes [x] No []

System head-ends

Check for physical and electrical security

Yes [x] No []

Check all channels off air and launch are correct

Yes [x] No []

Wiring

Inspect cable routes within the system

Yes [x] No []

ANNUAL SERVICE MAINTENANCE CONDITION REPORT



Additional notes:

Sky Q compatible – No

Inspected by: T Richards