



Fire Detection And Alarm System Maintenance Attendance Certificate

System serviced in accordance with BS5839-1

Site name & address Nuneaton + Bedworth Borough Council Cheveral Place Cheveral Street NUNEATON Post code CV11 5SF Contact name John Sweeney Telephone 024 7637 6464 Site Mobile Site e-mail Contract number MD-M30602	Call type Routine Maintenance Visit number 2 of 2 Visit date 13/01/2020 Job number 1179325 Appointment booked by Kate Gee System type Fire Detection and Alarm System Panel type Notifier ID2000 Panel location/number Customer Order Number Contract extension 4 Engineer name Jamie Bartlett
---	---

System and control equipment checks			
All relevant information/documentation available	p	Any structural change	y
Informed customer alarm on test	p	Sounders/beacons/bells tested	y
Checked log book for previous faults/activations	p	System coverage satisfactory	p
Identified devices/areas tested on previous visits	p	Zones tested	1st floor corridor and flats
System free from false alarms since last serviced	NA	All batteries tested	p
False alarms entered in log book	y	Site Log book completed	p
Relevant detail/defects explained and entered in log book	p	Return visit required	y
Equipment as per specification where known	p	Number of triggers tested	61
All cables undamaged where seen	p	Percentage of devices tested on this visit	50
Equipment firmly fixed	p	False alarms	
Equipment clean/undamaged	p	False alarms within the last 12 months	0
Correctly fitted & undamaged	p	Number of trigger devices on system	206
Functions tested	p	Number of false alarms per 100 trigger devices per annum	0 %
Display/LEDs tested	p		
Auxiliary relays tested	y		
Automatic transmission tested to ARC	NA		
Cause & effect tested	y		
Network tested	NA		
Shutdowns tested	NA		
Cause of false alarms eliminated	NA		
Outputs tested	y		
Aspirating detection tested if applicable	NA		

Have you returned the system to its normal operational state to the best of your knowledge
Yes If not why?
Further visit required? No

Works completed/engineer findings
routine fire alarm service all ok tested 1st floor corridor and flats 1-7-12-15-16-18-20-21-22-23-24-31 all ok no access to other areas due to access Sounders not tested due to customers request logbook completed all ok system left showing healthy

Works to be completed

Customer actions

Engineer	Call Date	Travel	Time On Site	Time Off Site	Arrive Back	Total Hours	Engineers Notes
----------	-----------	--------	--------------	---------------	-------------	-------------	-----------------

Jamie Bartlett	13/01/2020	11:00	11:30	16:20		5.33	
----------------	------------	-------	-------	-------	--	------	--

Declaration & Signatures

I / we being the competent persons responsible for the servicing of the fire detection and fire alarm system, particulars set out within this certificate CERTIFY that the said work for which I/ we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS5839-1.

Customer signature

Engineer signature



Customer name

Engineer name

Jamie Bartlett

Customer position

Reason for no signature if applicable: Not Present