



# Emergency Light Maintenance Attendance Certificate

System serviced in accordance with BS5266-1

Site name & address Nuneaton + Bedworth Borough Council Stan Williams Court  Glebe Road Nuneaton Post code CV11 4UJ Contact name John Sweeney Telephone 024 7637 6464 Site Mobile 07748 993 975 Site e-mail Contract number MD-M58673	Call type Routine Maintenance Visit date 18/09/2020 Job number 1255575 Appointment booked by Claire Long System type Emergency Lighting Panel type Central battery unit Panel location/number Customer Order Number Contract extension 4 Engineer Andrew Martin
--	---

<b>Site</b>  All relevant information and documentation available <input checked="" type="checkbox"/> Inform customer system on test NA Check log book for previous faults <input checked="" type="checkbox"/>  <b>Luminaires</b>  Main manufacturer/model 8w bulkheads Number of non-maintained luminaires 39 Number of non-maintained luminaires, maintained signs Number of maintained luminaires Number of slaves Duration of system tested 3 hour Total number tested 39 No. of luminaires failed 0	<b>Luminaires located at the following positions</b>  At each emergency exit door NA Within 2m of stair treads/level change NA Within 2m of exit and safety signs NA At intersection of corridors NA At each change of direction NA Outside and within 2m of final exits NA Within 2m of each first aid point NA Within 2m fire fighting equipment and call points NA  <b>Additional luminaires located at the following positions</b>  Lift cars NA Moving Stairways and walkways NA Disabled Toilets NA Motor generator room, control & plant rooms NA Covered car parks NA
---	--

<b>System status</b> Have you returned the system to its normal operational state to the best of your knowledge Yes If not why?
---

<b>Works completed/engineer findings</b>  3 hour emergency light test completed all areas tested no issues logbooks completed
--

<b>Works to be completed</b>  (Empty space for text)
--

<b>Customer actions &amp; recommendations</b>  (Empty space for text)
---

Timesheet	Call Date	Travel	Time On Site	Time Off Site	Arrive Back	Total Hours	Engineers Notes
Engineer							
Andrew Martin	18/09/2020	07:30	08:45	12:00		4.5	

<b>Customer signature</b>   <b>Customer Position</b> Reason for no signature if applicable: Not Presen	<b>Engineer signature</b>    <b>Engineer Name</b> Andrew Martin
--	---