



Emergency Light Maintenance Attendance Certificate

System serviced in accordance with BS5266-1

Site name & address Nuneaton + Bedworth Borough Council The Poplars Arbury Road Nuneaton Post code CV10 8JU Contact name John Sweeney Telephone 024 7637 6464 Site Mobile Site e-mail Contract number MD-M58677	Call type Routine Maintenance Visit date 01/10/2020 Job number 1256271 Appointment booked by Claire Long System type Emergency Lighting Panel type notifier id2000 Panel location/number Customer Order Number Contract extension 4 Engineer Andrew Martin
--	---

Site All relevant information and documentation available <input checked="" type="checkbox"/> Inform customer system on test NA Check log book for previous faults <input checked="" type="checkbox"/>	Luminaires located at the following positions At each emergency exit door NA Within 2m of stair treads/level change NA Within 2m of exit and safety signs NA At intersection of corridors NA At each change of direction NA Outside and within 2m of final exits NA Within 2m of each first aid point NA Within 2m fire fighting equipment and call points NA
Luminaires Main manufacturer/model 8w bulkheads Number of non-maintained luminaires 33 Number of non-maintained luminaires, maintained signs Number of maintained luminaires Number of slaves Duration of system tested 3 hour Total number tested 33 No. of luminaires failed 0	Additional luminaires located at the following positions Lift cars NA Moving Stairways and walkways NA Disabled Toilets NA Motor generator room, control & plant rooms NA Covered car parks NA

System status Have you returned the system to its normal operational state to the best of your knowledge Yes If not why?
--

Works completed/engineer findings 3 hour emergency light test completed all areas tested no issues logbooks completed
--

Works to be completed

Customer actions & recommendations

Timesheet	Call Date	Travel	Time On Site	Time Off Site	Arrive Back	Total Hours	Engineers Notes
Engineer							
Andrew Martin	30/09/2020	12:00	12:00	15:00		3	

Customer signature Customer Position Reason for no signature if applicable: Not Presen	Engineer signature Engineer Name Andrew Martin
---	---