



# Fire Detection And Alarm System Maintenance Attendance Certificate

System serviced in accordance with BS5839-1

Site name & address    Nuneaton + Bedworth Borough Council Sunnyside Court  Croft Road Nuneaton Post code                    CV10 7EG Contact name                John Sweeney Telephone                    024 7637 6464    Site Mobile    07765 896710 Site e-mail                    trinityrecords@nuneatonandbedworth.gov.uk Contract number            MD-M30615	Call type                      Routine Maintenance Visit number                 2 of 2 Visit date                     16/04/2021 Job number                    -1328785 Appointment booked by    Kate Gee System type                  Fire Detection and Alarm System Panel type                     notifier id2000 Panel location/number Customer Order Number    Contract extension 4 Engineer name                Andrew Martin
---	---

System and control equipment checks			
All relevant information/documentation available	p	Any structural change	y
Informed customer alarm on test	NA	Sounders/beacons/bells tested	p
Checked log book for previous faults/activations	p	System coverage satisfactory	p
Identified devices/areas tested on previous visits	p	Zones tested	
System free from false alarms since last serviced	p	All batteries tested	y
False alarms entered in log book	..	Site Log book completed	p
Relevant detail/defects explained and entered in log book	..	Return visit required	y
Equipment as per specification where known	p	Number of triggers tested	0
All cables undamaged where seen	p	Percentage of devices tested on this visit	0
Equipment firmly fixed	p	<b>False alarms</b>	
Equipment clean/undamaged	p	False alarms within the last 12 months	0
Correctly fitted & undamaged	p	Number of trigger devices on system	1
Functions tested	p	Number of false alarms per 100 trigger devices per annum	0 %
Display/LEDs tested	p		
Auxiliary relays tested	NA		
Automatic transmission tested to ARC	NA		
Cause & effect tested	NA		
Network tested	NA		
Shutdowns tested	NA		
Cause of false alarms eliminated	p		
Outputs tested	p		
Aspirating detection tested if applicable	NA		

<b>Have you returned the system to its normal operational state to the best of your knowledge</b>
Yes    If not why?
Further visit required?    No

<b>Works completed/engineer findings</b>
arrived onsite to re fit smoke detector in old store room refitted device to ceiling all fitted and tested no issues system still showing suspect break on loop 1 no devices lost, need two men for a morning to investigate fault panel left with suspect break loop 1

<b>Works to be completed</b>

<b>Customer actions</b>

Timesheet	Call Date	Travel	Time On Site	Time Off Site	Arrive Back	Total Hours	Engineers Notes
Engineer	16/04/2021	07:30	08:30	09:45		2.25	
Andrew Martin							

**Declaration & Signatures**

**I / we being the competent persons responsible for the servicing of the fire detection and fire alarm system, particulars set out within this certificate CERTIFY that the said work for which I/ we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS5839-1.**

**Customer signature**

-----

**Engineer signature**

-----

**Customer name**

.

**Customer position**

.

**Engineer name**

Andrew Martin

Reason for no signature if applicable: Not Present