



# Fire Detection And Alarm System Maintenance Attendance Certificate

System serviced in accordance with BS5839-1

Site name & address    Nuneaton + Bedworth Borough Council John Haynes Court Complex  School Lane Bedworth Post code                    CV7 9GG Contact name                John Sweeney Telephone                    024 7637 6464    Site Mobile    07884475915 Site e-mail                    trinityrecords@nuneatonandbedworth.gov.uk Contract number            MD-M30628	Call type                      Routine Maintenance Visit number                1 of 2 Visit date                    16/08/2021 Job number                    -1383825 Appointment booked by    Kate Gee System type                  Fire Detection and Alarm System Panel type                    Notifier ID3000 Panel location/number Customer Order Number    ES000767 Engineer name                Jamie Bartlett
--	---

System and control equipment checks			
All relevant information/documentation available	p	Any structural change	y
Informed customer alarm on test	p	Sounders/beacons/bells tested	y
Checked log book for previous faults/activations	p	System coverage satisfactory	p
Identified devices/areas tested on previous visits	p	Zones tested	see report
System free from false alarms since last serviced	NA	All batteries tested	p
False alarms entered in log book	y	Site Log book completed	p
Relevant detail/defects explained and entered in log book	p	Return visit required	y
Equipment as per specification where known	p	Number of triggers tested	61
All cables undamaged where seen	p	Percentage of devices tested on this visit	50
Equipment firmly fixed	p	<b>False alarms</b>	
Equipment clean/undamaged	p	False alarms within the last 12 months	0
Correctly fitted & undamaged	p	Number of trigger devices on system	1
Functions tested	p	Number of false alarms per 100 trigger devices per annum	0 %
Display/LEDs tested	p		
Auxiliary relays tested	y		
Automatic transmission tested to ARC	NA		
Cause & effect tested	y		
Network tested	NA		
Shutdowns tested	NA		
Cause of false alarms eliminated	NA		
Outputs tested	y		
Aspirating detection tested if applicable	NA		

<b>Have you returned the system to its normal operational state to the best of your knowledge</b>
Yes    If not why?
Further visit required?    No

<b>Works completed/engineer findings</b>
routine fire alarm service all ok tested Common areas and flats 28 20 19 18 16 13 12 7 3 outputs not tested due to customers request logbook completed all ok  system left showing power supply fault but Andy Martin is dealing with this

<b>Works to be completed</b>

<b>Customer actions</b>
-------------------------

**Timesheet**


Engineer	Call Date	Travel	Time On Site	Time Off Site	Arrive Back	Total Hours	Engineers Notes
Jamie Bartlett	16/08/2021	10:30	11:30	16:30	17:30	7	

**Declaration & Signatures**

**I / we being the competent persons responsible for the servicing of the fire detection and fire alarm system, particulars set out within this certificate CERTIFY that the said work for which I/ we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS5839-1.**

Customer signature

Engineer signature



Customer name

Engineer name

Jamie Bartlett

Customer position

Reason for no signature if applicable: Other